



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Drinking Water Report

Client Name: McMullen Water Systems
 P.O. Box 1471
 St. Helens, OR 97051

Reference Number: **18-30578**

Report Date: 8/21/18

Approved By: anp,tdp

Authorized by:

Thanh B Phan
 Lab Manager, Portland

Project: Robinette
 Field ID: 61000
 Sample Description: 61000 Robinette Road
 Sample Date: 8/16/18 10:00

Lab Number: 4072-61935

Date Received: 8/17/18

Sampled By: Shawn

Sampler Phone:

CAS Number	Analyte	Result	MCL	Pass	Lab	QL	Units
7440-38-2	ARSENIC	ND	0.010	Pass	a	0.001	mg/L
14797-55-8	NITRATE-N	0.04	10	Pass	c	0.005	mg/L
	TOTAL COLIFORM	Absent		Pass	c	P/A	per 100mL
	E. Coli	Absent		Pass	c	Y/N	per 100mL

Notation:

MCL = Maximum Contaminant Level, maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

QL = Quantitation Limit is the lower calibration concentration.

ND = Not detected above the listed specified reporting limit (QL).

CAS Number = Chemical Abstract Service Number is a unique identifier of the chemical tested.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through OR DEQ or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.