

PERMIT

SUBSURFACE ON-SITE SEWAGE TREATMENT SYSTEM

Environmental Health Program, Courthouse Room 308
256-2770

Date: 11/29/02 Building Permit #: A54-02

YCCHD Permit #: 12182

Site Location: 4611 Cheyenne Trail

Legal Description: Indian Cliffs 2nd Lot 4 Block 11 Tract

Installer: Jerry Burright

Installed for: Jerry & Diane Burright

Type of Dwelling: SFR Constructed for: 3 bedrooms / _____ gal/day.

Minimum Drainfield Size Requirements: 250 square feet/bedroom.

Total minimum amount of drainfield to be installed: 750 square feet; or 375 lineal feet.

Percolation Rate _____ minutes/inch Groundwater Depth _____ feet.

Water Supply: Well _____ Cistern Public _____ Other _____

Distance to Septic Tank 41' Distance to Drainfield 56'

Layout Details:

Tank Size: 1000 1500 _____ 2000 gallons; other _____

Material: Concrete Other _____ Tank to Foundation: 10'

Effluent Filter: Yes No

Trench Dimensions:

Gravel above pipe: 2" Depth to perf. pipe: 10"-24"

Gravel below pipe: 6" Depth to bottom trench: 18"-36"

Trench width: 24" Trench Nearest to Property Line: 26' North


System Type: Standard

Total Area Installed: 750 Sq. Ft.

75'
x 5

375
x 2

750



Approved: Denied: _____ Reason: _____

Installer: Jerry Burright Sanitarian: Scott Wendell, R.S.

Note: Inspection denotes compliance to plans submitted and to Yellowstone City-County Board of Health Rules and Regulations. It does not guarantee performance or longevity of system. (septic-permit - 06/01) *pd*