



**SNOHOMISH
HEALTH
DISTRICT**

Healthy Lifestyles, Healthy Communities

ENVIRONMENTAL HEALTH DIVISION
Water & Wastewater Section
3020 Rucker Avenue, Suite 104
Everett, WA 98201-3900
425.339.5250

RECEIVED
JUN 28 2013
Snohomish
Health District

ONSITE SEWAGE DISPOSAL SYSTEM PLAN (AS-BUILT)

Type of System: Gravity LPD SF Mound Repair
 Reduced System Other

Permit No. 35986 ~~56286~~ Property Tax Account No. 004576-005-001-00 Lot # 425-754-9772

Owner Name JAKE SHARPE

Owner Address 32901 138TH ST SE City SULTAN, WA Zip 98294

ADDRESS OF PROPERTY 600 6TH AND ORCHARD AVE City GOLD BAR

Legal Description GOLD BAR 1ST ADDN

Designer AMMAN SEPTIC DESIGNS Address 14525 246TH DR SE, MONROE, WA Phone 360-794-7809

Installer PROPERTY OWNER Address _____ Phone _____

Onsite Sewage Disposal System installed and approved for _____ # of bedrooms, or 330 sq. ft. of absorption area installed for 330 gal. per day.

I hereby certify the accompanying documentation is an accurate representation of the system installed at the above referenced property. I also certify all requirements listed on the approved Application for Onsite Sewage Disposal Permit dated 11/12/2009 have been complied with.

Signature of Designer or P.E. _____ License # 5100100 Date 11/01/2011

FOR HEALTH DISTRICT USE ONLY
 ACCEPTED NOT ACCEPTED DATE 7/8/13

Signature of Sanitarian [Signature]
Remarks _____

ATTENTION HOME OWNER

Your onsite sewage disposal system has limitations! It was designed and installed to care for an average sized family. Over-loading the septic tank or disturbance of the drainfield may seriously impair satisfactory operation. Points to remember:

1. Have your tank checked periodically to see if pumping is necessary (every 2 1/2 to 3 years).
2. Do not channel ground water, surface water, footing drains or downspouts into the tank or drainfield.
3. Do not excavate, fill, place a structure, driveway or patio in, on, or over the drainfield and its replacement area.
4. Limit toilet fixture disposal to sanitary wastes and toilet tissue.
5. Detergents and bleaches used in normal household quantities will not harm the action of the septic tank and disposal field.
6. Practice water conservation.
7. Snohomish Health District strongly recommends garbage grinders NOT be used.

It is the homeowners responsibility to insure the system is properly operated and maintained. Refer to the Operation and Maintenance material provided.

rev071503j
7-9-13
WEL