



145 N 19th Street  
 St. Helens, OR, 97051  
 503.397.1744  
 www.mcmullenwater.com

Tester Shawn  
 Flow test 1 hour  
 Address 61000 Robinette rd  
 Date & Time Started 8/16/2018  
 Source  
 Equipment 3/4 HP Control box : Iron filter

Time Minutes	Flow GPM	Pressure	Gallons Pumped	Static Level	Meter Reading	Notes
0		40		5	53103	
10		10	60	19	53163	
20		10	49	21	53212	
30		10	51	21	53263	
40		10	47	22	53310	
50		10	48	22	53358	
60		10	52	22	53410	
70						
80						
90						
100						
110						
120						
130						
140						
150						
160						
170						
180						
190						
200						
210						
220						
230						
240						

Total Gallons Pumped- 307 gallons over 1 hour  
 Average Flow in GPM- averaged at 5.1 Gallons per minute over 1 hour  
 Flow Test is only representative of date and time test performed.

Disclaimer: This test is accurate only for the date taken. McMullen Water Systems has no opinion as to the performance of this water source at any other date other than the date of testing. Nor does McMullen Water Systems have any opinion on the quality of the water or its suitability for any particular use. McMullen Water Systems has no opinions, expressed or implied as to the condition of the equipment contained in this water system.