

**MONTANA WELL LOG REPORT**

**Other Options**

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is compiled electronically from the contents of the Ground Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

[Return to menu](#)  
[Plot this site in State Library Digital Atlas](#)  
[Plot this site in Google Maps](#)  
[View scanned well log\\_\(3/3/2011 1:52:54 PM\)](#)

**Site Name: REYNOLDS, CLINT**  
**GWIC Id: 260445**

**Section 1: Well Owner(s)**  
 1) REYNOLDS, CLINT (MAIL)  
 2930 WISE LANE  
 BILLINGS MT 59101 [09/24/2006]

**Section 2: Location**

Township	Range	Section	Quarter Sections	Geocode
02S	24E	23	SE¼ SE¼	
<b>County</b>				

YELLOWSTONE

Latitude	Longitude	Geomethod	Datum
45.6411412504	-108.722364049	TRS-SEC	NAD83
Ground Surface Altitude	Ground Surface Method	Datum	Date

Addition	Block	Lot
----------	-------	-----

**Section 3: Proposed Use of Water**  
 DOMESTIC (1)

**Section 4: Type of Work**  
 Drilling Method: ROTARY  
 Status: NEW WELL

**Section 5: Well Completion Date**  
 Date well completed: Sunday, September 24, 2006

**Section 6: Well Construction Details**

**Borehole dimensions**

From	To	Diameter
0	31	7.825

**Casing**

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-2	21	6	0.25		WELDED	STEEL

**Completion (Perf/Screen)**

From	To	Diameter	# of Openings	Size of Openings	Description
21	26	6		60	SCREEN-CONTINUOUS-STAINLESS

**Annular Space (Seal/Grout/Packer)**

From	To	Description	Cont. Fed?
0	0	BENTONITE	Y
20	20	RUBBER K PACKER	

**Section 7: Well Test Data**

Total Depth: 26  
 Static Water Level: 10  
 Water Temperature:

**Air Test \***

35 gpm with drill stem set at 30 feet for 3 hours.  
 Time of recovery 0.5 hours.  
 Recovery water level 10 feet.  
 Pumping water level    feet.

\* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

**Section 8: Remarks**

**Section 9: Well Log  
 Geologic Source**

Unassigned

From	To	Description
0	26	SAND AND GRAVEL
26	31	SHALE

**Driller Certification**

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

<b>Name:</b> CURTIS SCHELLE
<b>Company:</b> AMERICAN DRILLING & SUPPLY
<b>License No:</b> WWC-344
<b>Date Completed:</b> 9/24/2006