

FORM NO.
GWS 31
10/94

WELL CONSTRUCTION AND TEST REPORT

For Office Use Only

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER
1313 Sherman St., Rm 818, Denver, CO 80203

RECEIVED

AUG 16 2005

WATER RESOURCES
STATE ENGINEER
COLO.

1. WELL PERMIT NUMBER 263199

2. OWNER NAME(S) Scott Parks
 Mailing Address Box 774076
 City, ST, Zip Steamboat Springs, CO 80477
 Phone 970-879-3335

3. WELL LOCATION AS DRILLED: NW 1/4 SW 1/4, Sec. 5 Twp. 5N, Range 85W
 DISTANCES FROM SEC. LINES:
1700 ft. from S Sec. Line, and 900 ft. from W Sec. Line, OR
north or south east or west
 SUBDIVISION: _____ LOT _____ BLOCK _____ FILING (UNIT) _____
 STREET ADDRESS AT WELL LOCATION: _____

4. GROUND SURFACE ELEVATION: 7550 ft. DRILLING METHOD: Air Rotary
 DATE COMPLETED: 7-7-05 TOTAL DEPTH: 460 ft. DEPTH COMPLETED: 460

5. GEOLOGIC LOG:
 Depth - Description of Material (Type, Size, Color, Water Depth)
0-3 top soil
3-180 sandy clay
180-182 Gravel 1/gpm
182-280 sandy clay
280-295 sandstone, hard
295-385 sandy clay
385-387 gravel 1/gpm
387-460 sandy clay

REMARKS: _____

6. HOLE DIAM. (IN.) From (ft) To (ft)

9	0	40
6.5	40	460

7. PLAIN CASING

OD (in)	Kind	Wall Size	From (ft)	To (ft)
7	Steel	.188	+2	40
5	pvc	sch 40	10	180
			200	380
			440	460
PERF. CASING: Screen Slot Size: .20				
5	pvc	sch 40	180	200
			380	440

8. FILTER PACK:
 Material silica
 Size 8-12
 Interval 30 Sks

9. PACKER PLACEMENT:
 Type _____
 Depth _____


10. GROUTING RECORD:

Material	Amount	Density	Interval	Placement
Port	6 sks	6	10-40	Pour

11. DISINFECTION: Type: HTH 70% Amt. Used: 3 cups

12. WELL TEST DATA: Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well
 TESTING METHOD Air blow, 2 hours
 Static Level: 45 ft. Date/Time measured 7/8/05, Production Rate: 2 GPM
 Pumping Level: _____ ft. Date/Time measured _____, Test Length (hrs): _____
 Remarks: _____

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]
 CONTRACTOR: Stewart Water Well, Inc. Phone: 303-781-7330 Lic. No. 1286
 Mailing Address: 3850 S. Lincoln St., Englewood, CO 80113

Name/Title (Please type or print): George Stewart, Owner/Operator Signature:  Date: 8/11/05