

Owner: Corey Claborn Location: 24 Mountain Vista Dr, Big Timber Permit Number: 22-027

Permit Status:

Approved Denied _____

Need more information _____

Wastewater design flow 350 gpd Bedrooms _____ Tank(s) Required (1) 1500 gallon septic & (1) 500gal dose

Drainfield components 3 laterals, 87.5ft long, 3ft wide, max 1.5ft deep, dug level,

of gravelless chambers, connected to a properly bedded manifold,

and installed according to the approved lot layout and design

_____ call sanitarian for inspection before backfillling _____

Approved by  Permit valid until: 8/22/2024

Sweet Grass County Sanitarian



Sweet Grass
COUNTY

COPY

ONSITE WASTEWATER PERMIT

This is a permit to install a septic system. The Park County Sanitarian must be contacted 24 hours in advance to schedule an inspection before the system can be backfilled. After the system is approved, this becomes the permit to operate the septic system. **No changes can be made to the approved plans and specifications without approval from the Park County Sanitarian.**