COLORADO
Division of Water Resources
Department of Natural Resources

WELL PERMIT NUMBER 310863-

RECEIPT NUMBER 9602417

ORIGINAL PERMIT APPLICANT(S)

MICHAEL LACOST

TARA LACOST

APPROVED WELL LOCATION

Water Division: 6 Water District: 58
Designated Basin: N/A
Management District: N/A
County: ROUTT
Parcel Name: WILLOW CREEK PASS (FILING: 2)
Lot: A Block: Filing:
Physical Address: 26425 WILLOW GULLCH CLARK, CO 80428
SE 1/4 SW 1/4 Section 4 Township 9.0 N Range 85.0 W Sixth P.M.

Well to be constructed on specified tract of land

PERMIT TO CONSTRUCT A NEW WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.

2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.

3) Approved pursuant to CRS 37-92-602(3)(b)(I) and the letter from the State Engineer dated February 1, 2018 to the Routt County Planning Department.

4) The use of ground water from this well is limited to fire protection and ordinary household purposes inside not more than one (1) single family dwelling. This well is to be located on lot A, filing 2, Willow Creek Pass Subdivision, Routt County.

5) The pumping rate of this well shall not exceed 15 GPM.

6) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.1 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include a GPS location (UTM coordinates) pursuant to the Division of Water Resources' guidelines.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: http://www.water.state.co.us

NOTE: Assessor Tax Schedule Number: 240300001

Issued By JIM MARTIN

Date Issued: 9/10/2018

Expiration Date: 9/10/2020