



NOTE:
 THE AS-BUILT SEPTIC SYSTEM FOR LOT 5 HERITAGE TRAIL DOES NOT REQUIRE A VENT DUE TO THE AMOUNT OF COVER IS LESS THAN 3 FEET PER TITLE V.

AS BUILT TIES AND ELEVATIONS TO SEPTIC SYSTEM

DESCRIPTIONS	INV. OUT HOUSE	INV. IN SEPTIC TANK	SEPTIC TANK COVER	SEPTIC TANK COVER	SEPTIC TANK COVER	INV. IN SEPTIC TANK	INV. IN D-BOX	CENTER D-BOX	INV. OUT D-BOX TYPICAL	ELBOW TRENCH	ELBOW TRENCH	END TRENCH	END TRENCH	END TRENCH
P.T. #	1	2	3	4	5	6	7	8	9	10	11	12	13	14
A	—	—	—	—	—	—	—	51.70'	51.98'	57.52'	45.40'	78.48'	80.44'	84.90'
B	—	—	14.69"	12.61"	12.14"	—	—	47.78'	48.50'	55.26'	40.70'	60.36'	83.57'	71.98'
C	—	—	27.22"	29.30"	31.86"	—	—	—	—	—	—	80.68'	87.11'	93.72'
ELEV.	112.66	112.11	113.19	113.19	113.19	111.85	111.08	111.75	110.91	110.88	110.89	110.71	110.63	110.66

TIE POINTS A, B & C ARE TAKEN FROM THE OUTSIDE FOUNDATION CORNERS OF THE EXISTING BUILDING ON LOT 5



**SEPTIC SYSTEM AS-BUILT
 #21 HERITAGE TRAIL
 IN
 SCITUATE, MASS.**

SCALE: 1" = 20' 9-13-96

ROSS ENGINEERING COMPANY INC.
 PROFESSIONAL ENGINEERS - LAND SURVEYORS

883 MAIN STREET
 NORWELL, MASS. 02061
 (617) 658-1325