YELLOWSTONE CITY-COUNTY HEALTH DEPARTMENT
SUBSURFACE SEWAGE TREATMENT SYSTEM

PERMIT

DATE OF PERMIT 4/17/2000

BUILDING PERMIT (A) B 214-99 #
CLASS (1) 2
Y.C. PERMIT NO. 11220

SITE LOCATION 1920 Plateau Road

LEGAL DESCRIPTION Oxbow Subdiv. 2nd LOT 6 BLK 6 TRACT ____
Installer Len Crome
Installed For Ken Kunz

Type of Dwelling S.F.R. Constructed/designed for 3 Bdrms

WATER SUPPLY: Well ____ Cistern X 2-2200 gal. Public ____
Distance to septic tank 87' Distance to drainfield 107'

MINIMUM DRAINFIELD REQUIREMENTS: 175 Sq. Ft./Bdrm
Percolation Rate ____ min./in. Depth of Groundwater ____ Ft.

LAYOUT DETAILS:
Tank Size: 1000 (2) 1500; 2000 gal. Material: Concrete X Other ____
Tank to Foundation: 26' Ft. Trench to property line 10½ Ft. E.

TRENCH DIMENSIONS:
Gravel above pipe 2" in. Gravel below pipe 6" in.
Depth to perf. pipe 20-26" in. Depth to bottom trench 30-36 in.
Trench width 24" System type standard

Total Area Installed: 532 sq ft.

3
59
59
59
59
20
266
2
532 sq ft.



APPROVED: X DENIED: ____ REASON:

INSTALLER Len Crome SANITARIAN T. Kylander, R.S.

NOTE: Inspection denotes compliance to plans submitted and to Yellowstone County Rules and Regulations. It does not guarantee performance or longevity of system. PD

permit.frm/10/94